

9. Combination Table

MU4R25

Indoor Unit Operating (Capacity Index, kBtu/h)						Total Capacity						Input (W)		
						Min		Rated		Max				
Unit-A	Unit-B	Unit-C	Unit-D	Unit-E	Total	Btu/h	kW	Btu/h	kW	Btu/h	kW	Min	Rated	Max
5	5	-	-	-	10	6,000	1.76	10,000	2.93	12,000	3.52	291	582	872
5	7	-	-	-	12	7,200	2.11	12,000	3.52	14,400	4.22	367	735	1,102
5	9	-	-	-	14	8,400	2.46	14,000	4.10	16,800	4.92	453	905	1,358
7	7	-	-	-	14	8,400	2.46	14,000	4.10	16,800	4.92	453	905	1,358
7	9	-	-	-	16	9,600	2.81	16,000	4.69	19,200	5.63	548	1,096	1,645
5	12	-	-	-	17	10,200	2.99	17,000	4.98	20,400	5.98	600	1,201	1,801
9	9	-	-	-	18	10,800	3.17	18,000	5.28	21,600	6.33	656	1,311	1,967
7	12	-	-	-	19	11,400	3.34	19,000	5.57	22,800	6.68	715	1,429	2,144
5	15	-	-	-	20	12,000	3.52	20,000	5.86	24,000	7.03	778	1,555	2,333
9	12	-	-	-	21	12,600	3.69	21,000	6.15	25,200	7.39	845	1,690	2,535
7	15	-	-	-	22	13,200	3.87	22,000	6.45	26,400	7.74	917	1,835	2,752
5	18	-	-	-	23	13,800	4.04	23,000	6.74	27,600	8.09	980	1,961	2,941
9	15	-	-	-	24	14,400	4.22	24,000	7.03	29,000	8.50	1,079	2,158	3,236
12	12	-	-	-	24	14,400	4.22	24,000	7.03	29,000	8.50	1,079	2,158	3,236
7	18	-	-	-	25	14,400	4.22	24,000	7.03	29,000	8.50	1,060	2,119	3,236
9	18	-	-	-	27	14,400	4.22	24,000	7.03	29,000	8.50	1,053	2,107	3,236
12	15	-	-	-	27	14,400	4.22	24,000	7.03	29,000	8.50	1,069	2,138	3,236
5	24	-	-	-	29	14,400	4.22	24,000	7.03	29,000	8.50	1,042	2,084	3,236
12	18	-	-	-	30	14,400	4.22	24,000	7.03	29,000	8.50	1,044	2,088	3,236
15	15	-	-	-	30	14,400	4.22	24,000	7.03	29,000	8.50	1,060	2,119	3,236
7	24	-	-	-	31	14,400	4.22	24,000	7.03	29,000	8.50	1,036	2,072	3,236
9	24	-	-	-	33	14,400	4.22	24,000	7.03	29,000	8.50	1,035	2,070	3,236
15	18	-	-	-	33	14,400	4.22	24,000	7.03	29,000	8.50	1,035	2,070	3,236
12	24	-	-	-	36	14,400	4.22	24,000	7.03	29,000	8.50	1,021	2,042	3,236
18	18	-	-	-	36	14,400	4.22	24,000	7.03	29,000	8.50	1,011	2,022	3,236
15	24	-	-	-	39	14,400	4.22	24,000	7.03	29,000	8.50	1,012	2,024	3,236
5	5	5	-	-	15	9,000	2.64	15,000	4.40	18,000	5.28	429	858	1,288
5	5	7	-	-	17	10,200	2.99	17,000	4.98	20,400	5.98	516	1,032	1,549
5	5	9	-	-	19	11,400	3.34	19,000	5.57	22,800	6.68	615	1,229	1,844
5	7	7	-	-	19	11,400	3.34	19,000	5.57	22,800	6.68	615	1,229	1,844
5	7	9	-	-	21	12,600	3.69	21,000	6.15	25,200	7.39	727	1,454	2,180
7	7	7	-	-	21	12,600	3.69	21,000	6.15	25,200	7.39	727	1,454	2,180
5	5	12	-	-	22	13,200	3.87	22,000	6.45	26,400	7.74	789	1,578	2,367
5	9	9	-	-	23	13,800	4.04	23,000	6.74	27,600	8.09	856	1,711	2,567
7	7	9	-	-	23	13,800	4.04	23,000	6.74	27,600	8.09	856	1,711	2,567
5	7	12	-	-	24	14,400	4.22	24,000	7.03	29,000	8.50	928	1,856	2,783
5	5	15	-	-	25	14,400	4.22	24,000	7.03	29,000	8.50	925	1,850	2,783
7	9	9	-	-	25	14,400	4.22	24,000	7.03	29,000	8.50	925	1,850	2,783
5	9	12	-	-	26	14,400	4.22	24,000	7.03	29,000	8.50	922	1,844	2,783
7	7	12	-	-	26	14,400	4.22	24,000	7.03	29,000	8.50	922	1,844	2,783
5	7	15	-	-	27	14,400	4.22	24,000	7.03	29,000	8.50	919	1,839	2,783
9	9	9	-	-	27	14,400	4.22	24,000	7.03	29,000	8.50	919	1,839	2,783
5	5	18	-	-	28	14,400	4.22	24,000	7.03	29,000	8.50	917	1,834	2,783
7	9	12	-	-	28	14,400	4.22	24,000	7.03	29,000	8.50	917	1,834	2,783
5	9	15	-	-	29	14,400	4.22	24,000	7.03	29,000	8.50	914	1,828	2,783
5	12	12	-	-	29	14,400	4.22	24,000	7.03	29,000	8.50	914	1,828	2,783
7	7	15	-	-	29	14,400	4.22	24,000	7.03	29,000	8.50	914	1,828	2,783
5	7	18	-	-	30	14,400	4.22	24,000	7.03	29,000	8.50	898	1,796	2,783
9	9	12	-	-	30	14,400	4.22	24,000	7.03	29,000	8.50	911	1,823	2,783
7	9	15	-	-	31	14,400	4.22	24,000	7.03	29,000	8.50	909	1,817	2,783

9. Combination Table

Indoor Unit Operating (Capacity index, kBtu/h)						Total Capacity						Input (W)		
						Min		Rated		Max				
Unit-A	Unit-B	Unit-C	Unit-D	Unit-E	Total	Btu/h	kW	Btu/h	kW	Btu/h	kW	Min	Rated	Max
7	12	12	-	-	31	14,400	4.22	24,000	7.03	29,000	8.50	909	1,817	2,783
5	12	15	-	-	32	14,400	4.22	24,000	7.03	29,000	8.50	906	1,812	2,783
5	9	18	-	-	32	14,400	4.22	24,000	7.03	29,000	8.50	893	1,785	2,783
7	7	18	-	-	32	14,400	4.22	24,000	7.03	29,000	8.50	893	1,785	2,783
9	9	15	-	-	33	14,400	4.22	24,000	7.03	29,000	8.50	903	1,807	2,783
9	12	12	-	-	33	14,400	4.22	24,000	7.03	29,000	8.50	903	1,807	2,783
5	5	24	-	-	34	14,400	4.22	24,000	7.03	29,000	8.50	883	1,766	2,783
7	9	18	-	-	34	14,400	4.22	24,000	7.03	29,000	8.50	887	1,775	2,783
7	12	15	-	-	34	14,400	4.22	24,000	7.03	29,000	8.50	901	1,802	2,783
5	12	18	-	-	35	14,400	4.22	24,000	7.03	29,000	8.50	885	1,770	2,783
5	15	15	-	-	35	14,400	4.22	24,000	7.03	29,000	8.50	885	1,770	2,783
5	7	24	-	-	36	14,400	4.22	24,000	7.03	29,000	8.50	878	1,756	2,783
9	12	15	-	-	36	14,400	4.22	24,000	7.03	29,000	8.50	896	1,791	2,783
12	12	12	-	-	36	14,400	4.22	24,000	7.03	29,000	8.50	896	1,791	2,783
9	9	18	-	-	36	14,400	4.22	24,000	7.03	29,000	8.50	882	1,765	2,783
7	12	18	-	-	37	14,400	4.22	24,000	7.03	29,000	8.50	880	1,760	2,783
7	15	15	-	-	37	14,400	4.22	24,000	7.03	29,000	8.50	893	1,786	2,783
5	9	24	-	-	38	14,400	4.22	24,000	7.03	29,000	8.50	873	1,746	2,783
5	15	18	-	-	38	14,400	4.22	24,000	7.03	29,000	8.50	877	1,754	2,783
7	7	24	-	-	38	14,400	4.22	24,000	7.03	29,000	8.50	873	1,746	2,783
9	12	18	-	-	39	14,400	4.22	24,000	7.03	29,000	8.50	875	1,749	2,783
9	15	15	-	-	39	14,400	4.22	24,000	7.03	29,000	8.50	888	1,776	2,783
12	12	15	-	-	39	14,400	4.22	24,000	7.03	29,000	8.50	888	1,776	2,783
5	5	5	5	-	20	12,000	3.52	20,000	5.86	24,000	7.03	674	1,348	2,023
5	5	5	7	-	22	13,200	3.87	22,000	6.45	26,400	7.74	742	1,483	2,225
5	5	5	9	-	24	14,400	4.22	24,000	7.03	29,000	8.50	872	1,744	2,616
5	5	7	7	-	24	14,400	4.22	24,000	7.03	29,000	8.50	872	1,744	2,616
5	5	7	9	-	26	14,400	4.22	24,000	7.03	29,000	8.50	867	1,734	2,616
5	7	7	7	-	26	14,400	4.22	24,000	7.03	29,000	8.50	867	1,734	2,616
5	5	5	12	-	27	14,400	4.22	24,000	7.03	29,000	8.50	864	1,729	2,616
5	5	9	9	-	28	14,400	4.22	24,000	7.03	29,000	8.50	862	1,724	2,616
5	7	7	9	-	28	14,400	4.22	24,000	7.03	29,000	8.50	862	1,724	2,616
7	7	7	7	-	28	14,400	4.22	24,000	7.03	29,000	8.50	862	1,724	2,616
5	5	7	12	-	29	14,400	4.22	24,000	7.03	29,000	8.50	859	1,718	2,616
5	5	5	15	-	30	14,400	4.22	24,000	7.03	29,000	8.50	857	1,713	2,616
5	7	9	9	-	30	14,400	4.22	24,000	7.03	29,000	8.50	857	1,713	2,616
7	7	7	9	-	30	14,400	4.22	24,000	7.03	29,000	8.50	857	1,713	2,616
5	5	9	12	-	31	14,400	4.22	24,000	7.03	29,000	8.50	854	1,708	2,616
5	7	7	12	-	31	14,400	4.22	24,000	7.03	29,000	8.50	854	1,708	2,616
5	5	7	15	-	32	14,400	4.22	24,000	7.03	29,000	8.50	852	1,703	2,616
5	9	9	9	-	32	14,400	4.22	24,000	7.03	29,000	8.50	852	1,703	2,616
7	7	9	9	-	32	14,400	4.22	24,000	7.03	29,000	8.50	852	1,703	2,616
5	5	5	18	-	33	14,400	4.22	24,000	7.03	29,000	8.50	837	1,673	2,616
5	7	9	12	-	33	14,400	4.22	24,000	7.03	29,000	8.50	849	1,698	2,616
7	7	7	12	-	33	14,400	4.22	24,000	7.03	29,000	8.50	849	1,698	2,616
5	5	9	15	-	34	14,400	4.22	24,000	7.03	29,000	8.50	847	1,693	2,616
5	5	12	12	-	34	14,400	4.22	24,000	7.03	29,000	8.50	847	1,693	2,616
5	7	7	15	-	34	14,400	4.22	24,000	7.03	29,000	8.50	847	1,693	2,616
7	9	9	9	-	34	14,400	4.22	24,000	7.03	29,000	8.50	847	1,693	2,616
5	5	7	18	-	35	14,400	4.22	24,000	7.03	29,000	8.50	844	1,688	2,616
5	9	9	12	-	35	14,400	4.22	24,000	7.03	29,000	8.50	844	1,688	2,616

9. Combination Table

Indoor Unit Operating (Capacity index, kBtu/h)						Total Capacity						Input (W)		
						Min		Rated		Max				
Unit-A	Unit-B	Unit-C	Unit-D	Unit-E	Total	Btu/h	kW	Btu/h	kW	Btu/h	kW	Min	Rated	Max
7	7	9	12	-	35	14,400	4.22	24,000	7.03	29,000	8.50	844	1,688	2,616
5	7	9	15	-	36	14,400	4.22	24,000	7.03	29,000	8.50	842	1,684	2,616
5	7	12	12	-	36	14,400	4.22	24,000	7.03	29,000	8.50	842	1,684	2,616
7	7	7	15	-	36	14,400	4.22	24,000	7.03	29,000	8.50	842	1,684	2,616
9	9	9	9	-	36	14,400	4.22	24,000	7.03	29,000	8.50	842	1,684	2,616
5	5	9	18	-	37	14,400	4.22	24,000	7.03	29,000	8.50	827	1,654	2,616
5	5	12	15	-	37	14,400	4.22	24,000	7.03	29,000	8.50	839	1,679	2,616
5	7	7	18	-	37	14,400	4.22	24,000	7.03	29,000	8.50	827	1,654	2,616
7	9	9	12	-	37	14,400	4.22	24,000	7.03	29,000	8.50	839	1,679	2,616
5	9	9	15	-	38	14,400	4.22	24,000	7.03	29,000	8.50	837	1,674	2,616
5	9	12	12	-	38	14,400	4.22	24,000	7.03	29,000	8.50	837	1,674	2,616
7	7	9	15	-	38	14,400	4.22	24,000	7.03	29,000	8.50	837	1,674	2,616
7	7	12	12	-	38	14,400	4.22	24,000	7.03	29,000	8.50	837	1,674	2,616
5	5	5	24	-	39	14,400	4.22	24,000	7.03	29,000	8.50	818	1,636	2,616
5	7	9	18	-	39	14,400	4.22	24,000	7.03	29,000	8.50	822	1,644	2,616
5	7	12	15	-	39	14,400	4.22	24,000	7.03	29,000	8.50	835	1,669	2,616
9	9	9	12	-	39	14,400	4.22	24,000	7.03	29,000	8.50	835	1,669	2,616
7	7	7	18	-	39	14,400	4.22	24,000	7.03	29,000	8.50	822	1,644	2,616

Note

■ Capacities are based on the following conditions :

- Cooling : Indoor Ambient Temp. 27°CDB / 19°CWB, Outdoor Ambient Temp. 35°CDB / 24°CWB

- Heating : Indoor Ambient Temp. 20°CDB / 15°CWB, Outdoor Ambient Temp. 7°CDB / 6°CWB

- Interconnected piping is standard length and difference of Elevation (Outdoor ~ Indoor Unit) is 0 m.

■ At least two indoor units should be connected. And minimum limit of combination ratio is 40% approximately for rated capacity of outdoor unit.

■ Don't exceed the maximum connectable indoor units number, it can be found in Specifications or combination table of outdoor unit model.

9. Combination Table

MU4R25

Indoor Unit Operating (Capacity Index, kBtu/h)						Total Capacity						Input (W)		
						Min		Rated		Max				
Unit-A	Unit-B	Unit-C	Unit-D	Unit-E	Total	Btu/h	kW	Btu/h	kW	Btu/h	kW	Min	Rated	Max
5	5	-	-	-	10	6,900	2.02	11,500	3.37	13,225	3.88	334	667	1,001
5	7	-	-	-	12	8,280	2.43	13,800	4.04	15,870	4.65	417	835	1,252
5	9	-	-	-	14	9,660	2.83	16,100	4.72	18,515	5.43	509	1,018	1,527
7	7	-	-	-	14	9,660	2.83	16,100	4.72	18,515	5.43	509	1,018	1,527
7	9	-	-	-	16	11,040	3.24	18,400	5.39	21,160	6.20	609	1,218	1,827
5	12	-	-	-	17	11,730	3.44	19,550	5.73	22,482	6.59	663	1,325	1,988
9	9	-	-	-	18	12,420	3.64	20,700	6.07	23,805	6.98	719	1,438	2,157
7	12	-	-	-	19	13,110	3.84	21,850	6.40	25,127	7.36	778	1,556	2,334
5	15	-	-	-	20	13,800	4.04	23,000	6.74	26,450	7.75	840	1,681	2,521
9	12	-	-	-	21	14,490	4.25	24,150	7.08	27,772	8.14	906	1,812	2,718
7	15	-	-	-	22	15,180	4.45	25,300	7.42	29,095	8.53	975	1,950	2,925
5	18	-	-	-	23	15,870	4.65	26,450	7.75	30,417	8.91	1,033	2,065	3,098
9	15	-	-	-	24	16,560	4.85	27,600	8.09	31,000	9.09	1,125	2,251	3,165
12	12	-	-	-	24	16,560	4.85	27,600	8.09	31,000	9.09	1,125	2,251	3,165
7	18	-	-	-	25	16,560	4.85	27,600	8.09	31,000	9.09	1,106	2,211	3,165
9	18	-	-	-	27	16,560	4.85	27,600	8.09	31,000	9.09	1,099	2,198	3,165
12	15	-	-	-	27	16,560	4.85	27,600	8.09	31,000	9.09	1,115	2,231	3,165
5	24	-	-	-	29	16,560	4.85	27,600	8.09	31,000	9.09	1,087	2,174	3,165
12	18	-	-	-	30	16,560	4.85	27,600	8.09	31,000	9.09	1,089	2,178	3,165
15	15	-	-	-	30	16,560	4.85	27,600	8.09	31,000	9.09	1,106	2,211	3,165
7	24	-	-	-	31	16,560	4.85	27,600	8.09	31,000	9.09	1,081	2,161	3,165
9	24	-	-	-	33	16,560	4.85	27,600	8.09	31,000	9.09	1,074	2,149	3,165
15	18	-	-	-	33	16,560	4.85	27,600	8.09	31,000	9.09	1,074	2,149	3,165
12	24	-	-	-	36	16,560	4.85	27,600	8.09	31,000	9.09	1,065	2,130	3,165
18	18	-	-	-	36	16,560	4.85	27,600	8.09	31,000	9.09	1,055	2,109	3,165
15	24	-	-	-	39	16,560	4.85	27,600	8.09	31,000	9.09	1,056	2,112	3,165
5	5	5	-	-	15	10,350	3.03	17,250	5.06	19,838	5.81	480	959	1,439
5	5	7	-	-	17	11,730	3.44	19,550	5.73	22,482	6.59	570	1,140	1,710
5	5	9	-	-	19	13,110	3.84	21,850	6.40	25,127	7.36	669	1,338	2,008
5	7	7	-	-	19	13,110	3.84	21,850	6.40	25,127	7.36	669	1,338	2,008
5	7	9	-	-	21	14,490	4.25	24,150	7.08	27,772	8.14	779	1,558	2,337
7	7	7	-	-	21	14,490	4.25	24,150	7.08	27,772	8.14	779	1,558	2,337
5	5	12	-	-	22	15,180	4.45	25,300	7.42	29,095	8.53	839	1,677	2,516
5	9	9	-	-	23	15,870	4.65	26,450	7.75	30,417	8.91	901	1,803	2,704
7	7	9	-	-	23	15,870	4.65	26,450	7.75	30,417	8.91	901	1,803	2,704
5	7	12	-	-	24	16,560	4.85	27,600	8.09	31,000	9.09	968	1,936	2,853
5	5	15	-	-	25	16,560	4.85	27,600	8.09	31,000	9.09	965	1,930	2,853
7	9	9	-	-	25	16,560	4.85	27,600	8.09	31,000	9.09	965	1,930	2,853
5	9	12	-	-	26	16,560	4.85	27,600	8.09	31,000	9.09	962	1,924	2,853
7	7	12	-	-	26	16,560	4.85	27,600	8.09	31,000	9.09	962	1,924	2,853
5	7	15	-	-	27	16,560	4.85	27,600	8.09	31,000	9.09	959	1,919	2,853
9	9	9	-	-	27	16,560	4.85	27,600	8.09	31,000	9.09	959	1,919	2,853
5	5	18	-	-	28	16,560	4.85	27,600	8.09	31,000	9.09	942	1,885	2,853
7	9	12	-	-	28	16,560	4.85	27,600	8.09	31,000	9.09	956	1,913	2,853
5	9	15	-	-	29	16,560	4.85	27,600	8.09	31,000	9.09	954	1,907	2,853
5	12	12	-	-	29	16,560	4.85	27,600	8.09	31,000	9.09	954	1,907	2,853
7	7	15	-	-	29	16,560	4.85	27,600	8.09	31,000	9.09	954	1,907	2,853
5	7	18	-	-	30	16,560	4.85	27,600	8.09	31,000	9.09	937	1,873	2,853
9	9	12	-	-	30	16,560	4.85	27,600	8.09	31,000	9.09	951	1,902	2,853
7	9	15	-	-	31	16,560	4.85	27,600	8.09	31,000	9.09	948	1,896	2,853

9. Combination Table

Indoor Unit Operating (Capacity index, kBtu/h)						Total Capacity						Input (W)		
						Min		Rated		Max				
Unit-A	Unit-B	Unit-C	Unit-D	Unit-E	Total	Btu/h	kW	Btu/h	kW	Btu/h	kW	Min	Rated	Max
7	12	12	-	-	31	16,560	4.85	27,600	8.09	31,000	9.09	948	1,896	2,853
5	12	15	-	-	32	16,560	4.85	27,600	8.09	31,000	9.09	945	1,890	2,853
5	9	18	-	-	32	16,560	4.85	27,600	8.09	31,000	9.09	931	1,862	2,853
7	7	18	-	-	32	16,560	4.85	27,600	8.09	31,000	9.09	931	1,862	2,853
9	9	15	-	-	33	16,560	4.85	27,600	8.09	31,000	9.09	942	1,885	2,853
9	12	12	-	-	33	16,560	4.85	27,600	8.09	31,000	9.09	942	1,885	2,853
5	5	24	-	-	34	16,560	4.85	27,600	8.09	31,000	9.09	921	1,843	2,853
7	9	18	-	-	34	16,560	4.85	27,600	8.09	31,000	9.09	926	1,852	2,853
7	12	15	-	-	34	16,560	4.85	27,600	8.09	31,000	9.09	940	1,879	2,853
5	12	18	-	-	35	16,560	4.85	27,600	8.09	31,000	9.09	923	1,846	2,853
5	15	15	-	-	35	16,560	4.85	27,600	8.09	31,000	9.09	937	1,874	2,853
5	7	24	-	-	36	16,560	4.85	27,600	8.09	31,000	9.09	916	1,832	2,853
9	12	15	-	-	36	16,560	4.85	27,600	8.09	31,000	9.09	934	1,869	2,853
12	12	12	-	-	36	16,560	4.85	27,600	8.09	31,000	9.09	934	1,869	2,853
9	9	18	-	-	36	16,560	4.85	27,600	8.09	31,000	9.09	920	1,841	2,853
7	12	18	-	-	37	16,560	4.85	27,600	8.09	31,000	9.09	918	1,836	2,853
7	15	15	-	-	37	16,560	4.85	27,600	8.09	31,000	9.09	932	1,863	2,853
5	9	24	-	-	38	16,560	4.85	27,600	8.09	31,000	9.09	911	1,821	2,853
5	15	18	-	-	38	16,560	4.85	27,600	8.09	31,000	9.09	915	1,830	2,853
7	7	24	-	-	38	16,560	4.85	27,600	8.09	31,000	9.09	911	1,821	2,853
9	12	18	-	-	39	16,560	4.85	27,600	8.09	31,000	9.09	913	1,825	2,853
9	15	15	-	-	39	16,560	4.85	27,600	8.09	31,000	9.09	926	1,852	2,853
12	12	15	-	-	39	16,560	4.85	27,600	8.09	31,000	9.09	926	1,852	2,853
5	5	5	5	-	20	13,800	4.04	23,000	6.74	26,450	7.75	679	1,359	2,038
5	5	5	7	-	22	15,180	4.45	25,300	7.42	29,095	8.53	788	1,577	2,365
5	5	5	9	-	24	16,560	4.85	27,600	8.09	31,000	9.30	910	1,820	2,674
5	5	7	7	-	24	16,560	4.85	27,600	8.09	31,000	9.30	910	1,820	2,674
5	5	7	9	-	26	16,560	4.85	27,600	8.09	31,000	9.30	904	1,809	2,674
5	7	7	7	-	26	16,560	4.85	27,600	8.09	31,000	9.30	904	1,809	2,674
5	5	5	12	-	27	16,560	4.85	27,600	8.09	31,000	9.30	902	1,803	2,674
5	5	9	9	-	28	16,560	4.85	27,600	8.09	31,000	9.30	899	1,798	2,674
5	7	7	9	-	28	16,560	4.85	27,600	8.09	31,000	9.30	899	1,798	2,674
7	7	7	7	-	28	16,560	4.85	27,600	8.09	31,000	9.30	899	1,798	2,674
5	5	7	12	-	29	16,560	4.85	27,600	8.09	31,000	9.30	883	1,766	2,674
5	5	5	15	-	30	16,560	4.85	27,600	8.09	31,000	9.30	894	1,787	2,674
5	7	9	9	-	30	16,560	4.85	27,600	8.09	31,000	9.30	894	1,787	2,674
7	7	7	9	-	30	16,560	4.85	27,600	8.09	31,000	9.30	894	1,787	2,674
5	5	9	12	-	31	16,560	4.85	27,600	8.09	31,000	9.30	891	1,782	2,674
5	7	7	12	-	31	16,560	4.85	27,600	8.09	31,000	9.30	891	1,782	2,674
5	5	7	15	-	32	16,560	4.85	27,600	8.09	31,000	9.30	888	1,777	2,674
7	7	9	9	-	32	16,560	4.85	27,600	8.09	31,000	9.30	888	1,777	2,674
5	5	5	18	-	33	16,560	4.85	27,600	8.09	31,000	9.30	873	1,746	2,674
5	7	9	12	-	33	16,560	4.85	27,600	8.09	31,000	9.30	886	1,772	2,674
7	7	7	12	-	33	16,560	4.85	27,600	8.09	31,000	9.30	886	1,772	2,674
5	5	9	15	-	34	16,560	4.85	27,600	8.09	31,000	9.30	883	1,767	2,674
5	5	12	12	-	34	16,560	4.85	27,600	8.09	31,000	9.30	883	1,767	2,674
5	7	7	15	-	34	16,560	4.85	27,600	8.09	31,000	9.30	883	1,767	2,674
7	9	9	9	-	34	16,560	4.85	27,600	8.09	31,000	9.30	883	1,767	2,674
5	5	7	18	-	35	16,560	4.85	27,600	8.09	31,000	9.30	868	1,735	2,674
5	9	9	12	-	35	16,560	4.85	27,600	8.09	31,000	9.30	881	1,762	2,674
7	7	9	12	-	35	16,560	4.85	27,600	8.09	31,000	9.30	881	1,762	2,674

9. Combination Table

Indoor Unit Operating (Capacity index, kBtu/h)						Total Capacity						Input (W)		
						Min		Rated		Max				
Unit-A	Unit-B	Unit-C	Unit-D	Unit-E	Total	Btu/h	kW	Btu/h	kW	Btu/h	kW	Min	Rated	Max
5	7	9	15	-	36	16,560	4.85	27,600	8.09	31,000	9.30	878	1,756	2,674
5	7	12	12	-	36	16,560	4.85	27,600	8.09	31,000	9.30	878	1,756	2,674
7	7	7	15	-	36	16,560	4.85	27,600	8.09	31,000	9.30	878	1,756	2,674
9	9	9	9	-	36	16,560	4.85	27,600	8.09	31,000	9.30	878	1,756	2,674
5	5	9	18	-	37	16,560	4.85	27,600	8.09	31,000	9.30	863	1,725	2,674
5	5	12	15	-	37	16,560	4.85	27,600	8.09	31,000	9.30	876	1,751	2,674
5	7	7	18	-	37	16,560	4.85	27,600	8.09	31,000	9.30	863	1,725	2,674
7	9	9	12	-	37	16,560	4.85	27,600	8.09	31,000	9.30	876	1,751	2,674
5	9	9	15	-	38	16,560	4.85	27,600	8.09	31,000	9.30	873	1,746	2,674
7	7	9	15	-	38	16,560	4.85	27,600	8.09	31,000	9.30	873	1,746	2,674
7	7	12	12	-	38	16,560	4.85	27,600	8.09	31,000	9.30	873	1,746	2,674
5	5	5	24	-	39	16,560	4.85	27,600	8.09	31,000	9.30	854	1,707	2,674
5	7	9	18	-	39	16,560	4.85	27,600	8.09	31,000	9.30	858	1,716	2,674
5	7	12	15	-	39	16,560	4.85	27,600	8.09	31,000	9.30	871	1,741	2,674
9	9	9	12	-	39	16,560	4.85	27,600	8.09	31,000	9.30	871	1,741	2,674
7	7	7	18	-	39	16,560	4.85	27,600	8.09	31,000	9.30	858	1,716	2,674
9	9	9	12	-	39	14,400	4.22	24,000	7.03	29,000	8.50	835	1,669	2,616
7	7	7	18	-	39	14,400	4.22	24,000	7.03	29,000	8.50	822	1,644	2,616

Note

■ Capacities are based on the following conditions :

- Cooling : Indoor Ambient Temp. 27°CDB / 19°CWB, Outdoor Ambient Temp. 35°CDB / 24°CWB

- Heating : Indoor Ambient Temp. 20°CDB / 15°CWB, Outdoor Ambient Temp. 7°CDB / 6°CWB

- Interconnected piping is standard length and difference of Elevation (Outdoor ~ Indoor Unit) is 0 m.

■ At least two indoor units should be connected. And minimum limit of combination ratio is 40% approximately for rated capacity of outdoor unit.

■ Don't exceed the maximum connectable indoor units number, it can be found in Specifications or combination table of outdoor unit model.